



Joe Laydon < laydonj@grafton-ma.gov>

Comments Needed from Both on 34 East Street

graftonh20@aol.com <graftonh20@aol.com> To: laydonj@grafton-ma.gov

Mon, Dec 23, 2019 at 8:26 AM

Joe

I have viewed the plans attached. There is presently a water service feeding 34 Elm Street. The applicant would need to make application to the Water District for the extension of the water main as well as the replacement of the service for the property shown. At this time there is no approval from the District for this work. I do see many issues with the proposed plan that would not be subject to approval by us and would need to be changed or deleted. Specifically, water mains of this size, in easements, are not allowed by the District unless they are specifically for secondary backup supply or water quality issues.

Matt Pearson, Manager

RECEIVED

----Original Message----From: Joe Laydon laydonj@grafton-ma.gov

To: Grafton Water <graftonh20@aol.com>; Paul Cournoyer <cournoyerp@grafton-ma.gov>

Sent: Thu, Dec 19, 2019 3:28 pm

Subject: Comments Needed from Both on 34 East Street

[Quoted text hidden]

DEC 2 3 2019

PLANNING BOARD GRAFTON, MA

